

**CORRIGENDUM #01****SUPPLY OF NATURAL GAS REGULATOR IN NORTH GOA GA****Tender No : GNGPL/C&P/T-30****Tender ID : VCS2100005****VCS REFERENCE NO. VCS/GNGPL/1023/PRC/2021/002****Owner - GOA NATURAL GAS PVT. LTD.****Consultant - VCS Quality Services Private Limited****Date: 12.10.2021**

Sl. No.	Clause No.	Page No.	Description	Amendment/ Addition/ Modification/ Deletion	
COMMERCIAL					
1	Technical Vol.	27 & 28 of 31 (Technical Vol. II of II)	Datasheets For Commercial Regulator	Modification	Refer Annexure-1 for revised datasheets (Rev.1) of Group-D commercial regulator.
2	Technical Vol.	06 of 31 (Technical Vol. II of II)	Material Requisition	Modification	Refer Annexure-2 for revised description of goods and/or service of Group-D Commercial regulator (Rev.D2)
3	Schedule of rates (SOR)	Section VI	Schedule of rates (SOR)	Modification	Existing SOR is replaced with Revised SOR- (Rev.01), Bidder to submit offer in Revised SOR-Rev.01 format only else bid shall be rejected.
4	Commercial and technical Vol.		Commercial Regulator, Inlet:- 6 bar, Outlet:- 03 bar max.	Modification	Group-D Commercial Regulator, Inlet:- 6 bar, Outlet:- 01 to 02 bar max. Outlet pressure of commercial regulator for Sr. No 4, 5 & 6 of Group-D mentioned as 03 bar anywhere in tender document shall stands null & void and shall be considered as 01 to 02 bar max.

Note: This Corrigendum shall form an integral part of the bidding document and shall be signed/stamped and submitted along with the bid. All other terms and conditions of tender documents shall remain un-changed.