



REPLY TO BIDDER'S PRE-BID QUERIES
Subject :- ANNUAL RATE CONTRACT FOR CARRYING OUT HYDRO TESTING AND INSPECTION OF CNG CASCADE AS PER PESO REGULATIONS FOR GOA NATURAL GAS PVT LTD
Tender No.:- GNGPL/C&P/T-48 dated 05/01/2023

SL. No.	REFERENCE OF BIDDING DOCUMENT				BIDDER'S QUERY	GNGPL'S REPLY
	Sec No.	Page No.	Clause No.	Subject		
1	SECTION III -SCC	45 of 131	Clause No. 1 of SCC Sub-Clause 2	Scope of work at contractor's premises	Details of Nitrogen Purging to be done in cascades.	Refer Sub-clause 2.13, "Purging of all cylinders of cascade with nitrogen after fixing tubing and fittings and keeping the cascade under positive pressure of nitrogen while transporting from contractor's work shop to GNGPL site."
2	SECTION III -SCC	44 of 131	Clause No. 1 of SCC Sub-Clause 1	Scope of work at GNGPL site	Goa Natural Gas to transport cascade from their store to the delivery point where omkar will deliver cascade.	For the Cascade which is to be tested - Refer Sub-clause 1.6, "Contractor shall carry out transportation of cylinder cascade from GNGPL location to their work premises. E-way bill is also in the scope of the contractor" Loading/Unloading of CNG Cascade Cylinder at both GNGPL and Contractors premises shall be carried out by the successful bidder. For Spare Cascade which is to be installed at RO on temporary basis - Contractor shall install the spare cascade at CNG RO on temporary basis. All activities including Loading / Unloading / Transportation / Assembly / Disassembly of temporary cascade is in the scope of bidder only.



Amit Gokhale
17/1/23

Mr. Amit Gokhale
Sr. Manager - Projects, GNGPL

Note: Any addendum / corrigendum / clarifications shall be integral part of the Bidding Documents and shall be submitted by bidders duly signed & stamped in their bid.