

			REPLY TO BIDDER'S PRE-BID QUERIES TENDER FOR ANNUAL RATE CONTRACT FOR SUPPLY OF CAR-CUM AUTO DUAL ARM CNG DISPENSERS / SINGLE ARM CNG BUS DISPENSERS FOR CGD IN NORTH GOA TENDER NO. GNGPL/C&PT/-50 TENDER ID : VCS21000039			VCS Ref. No.: VCS/GNGPL/1023/PRC/2023/001 Owner - GOA NATURAL GAS PRIVATE LIMITED (GNGPL) Consultant - VCS Quality Services Pvt Ltd. Pre-bid meeting held on 03.05.2023 Date: 22.05.2023		
Sl. No.	Tender Clause No.	Tender Page No.	Description	Bidder's Query/Clarification	GNGPL/VCS Reply			
COMMERCIAL								
1	Commercial Volume II (3.1.1.3)	5 of 132	Comprehensive Annual Maintenance (CAMC) Contract of CAR-CUM AUTO (DUAL ARM) CNG Dispensers including repair, Calibration of Instruments & Dispenser, supply of consumables, Spare parts, Tools, & Manpower etc. after the 1st Year of warranty periods.	Client requirement is that CAMC should be post Warranty 9 years . Kindly note that as per SOR Requirement, it is not possible for Vendor same price for each year Price consecutively of 9 Years for CAMC during bidding Submission due to fluctuation of spares Prices every years. We request PMC to kindly amend the CAMC Clause limited upto only 4 years after that the fresh rate shall be quote accordingly . We request PMC to kindly amend the BEC Technical Criteria . As a Startup firm, We have supplied 12 nos of Car Dispenser to MIS HINDUSTAN PETROLEUM CORPORATION LIMITED (HPCL) and 1 No CNG Car Dispenser tender has been awarded to MIS IOCL. Our company is well equipped with modern machinery for assembly and Testing of CNG Dispenser with 2x7 Nitrogen Gas Plant setup by us and we have Technical Manpower who have vast experience in the Oil and Gas Industry. Also, as per Technical requirements for Both Car and Bus Dispenser Same Philosophy is being used for refuelling of Natural Gas to Vehicle the only difference is that for Bus Dispenser Single Bank is to be provided for Fast Filling from High Bank. We Request PMC to kindly allow us to participate in the Bidding Process for Bus Dispenser by modifying this clause not mandatory .	Client requirement is that CAMC should be post Warranty 9 years . Kindly note that as per SOR Requirement, it is not possible for Vendor same price for each year Price consecutively of 9 Years for CAMC during bidding Submission due to fluctuation of spares Prices every years. We request PMC to kindly amend the CAMC Clause limited upto only 4 years after that the fresh rate shall be quote accordingly . We request PMC to kindly amend the BEC Technical Criteria . As a Startup firm, We have supplied 12 nos of Car Dispenser to MIS HINDUSTAN PETROLEUM CORPORATION LIMITED (HPCL) and 1 No CNG Car Dispenser tender has been awarded to MIS IOCL. Our company is well equipped with modern machinery for assembly and Testing of CNG Dispenser with 2x7 Nitrogen Gas Plant setup by us and we have Technical Manpower who have vast experience in the Oil and Gas Industry. Also, as per Technical requirements for Both Car and Bus Dispenser Same Philosophy is being used for refuelling of Natural Gas to Vehicle the only difference is that for Bus Dispenser Single Bank is to be provided for Fast Filling from High Bank. We Request PMC to kindly allow us to participate in the Bidding Process for Bus Dispenser by modifying this clause not mandatory .	Tender condition shall prevail.		
2	BIDDER EVALUATION CRITERIA (TECHNICAL) 8.0 (Commercial Volume)	9 of 132	Supply of Single-Arm CNG Bus Dispenser-1 NOS			Tender condition shall prevail.		
3	PRICE REDUCTION SCHEDULE FOR DELAYED DELIVERY (26.0) (Commercial Volume)	60 of 132	In case of delay in delivery of equipment/materials or delay in completion, total contract price shall be reduced by 1/2 % (half percent) of the total contract price per complete week of delay or part thereof subject to a maximum of 5% (five percent) of the total contract price	We Request PMC to kindly amend the PRS Clause by changing the delay of delivery by 1/2 Percent of the total price of Call up order not by the Contract Price .	Please refer clause no. 26.4 of GCC, it is stated therein "In case of Annual Rate Contracts (ARC), the price reduction schedule to be made applicable against individual release order with specific delivery period and not on the total ARC value".			
4	Terms and mode of Payment (17.0) (Commercial Volume)	72 of 132	90% (Ninety percent) payment along with freight charges including all taxes & duties will be paid progressively on pro-rata basis on receipt & acceptance of goods at FOT site	We request PMC to kindly amend the clause of releasing 100 percent payment after receipt of materials at stores, site and acceptance of goods.	Tender condition shall prevail.			
5	Terms and mode of Payment (17.0) (Commercial Volume)	73 of 132	17.1.1 90% (Ninety percent) payment along with freight charges including all taxes & duties will be paid progressively on pro-rata basis on receipt & acceptance of goods at FOT site. 17.1.2 Balance 10% payment shall be released on submission of following document on closure of order.	Client to define timeline to release the balance 10% payment. As per standard it should be released against Installation and Commissioning or within 90 days of supply whichever is earlier in case I&C could not be done due to non readiness of site for reasons attributable to owner.	Refer Corrigendum #02 (In case Installation, Testing & Commissioning and Performance Acceptance Test could not be executed within 90 days from the date of receipt of Dispenser Unit package at site/ store due to reasons attributable to Purchaser, the 10% (Ten Percent) payment shall be released against submission of BG of equivalent amount valid till the Guarantee / Warranty period)			
6	5.0 CONTRACT PERIOD & DELIVERY SCHEDULE	70 of 132	5.1 Annual Rate Contract shall be for Three (03) years from the date of FOT	It is not feasible to provide rate validity for 3 years due to market dynamics as rates of sub assemblies keep revising each year due to dollar rate fluctuations, custom duties, market demand etc. Bidders request to limit ARC for 1 year only.	Tender condition shall prevail.			
7	AMC PERIOD	AMC PERIOD	Comprehensive Annual Maintenance (CAMC) Contract for a period of 10 years	It is not feasible to make estimations and quote for AMC rates for 10 years due to market dynamics as rates of spares keep revising each year due to dollar rate fluctuations, custom duties, market demand, Manpower cost etc. Bidders request to limit CAMC period to maximum 4 years subject to revision thereafter so that bidder can quote genuine and most competitive rates.	Tender condition shall prevail.			
8	BRIEF SCOPE	4 of 132	Statutory clearance from W&M India for the field installation before the start of commercial operations is in the bidder's scope.	Bidder shall provide only technical support for W&M stamping before the start of commercial operation of dispensers. All lissensing and statutory annual stamping fees to W&M dept. shall be in scope of client	Bidder shall have single point responsibility for supply of CNG Dispenser along with valid W&M certificate for Manufacturing, Repair & Dealer for the field installation technical support during W&M stamping , except All lissensing and statutory annual stamping fees to W&M dept shall be in the scope of client.			
9	3. BRIEF SCOPE OF WORK	5 of 134	CAR-CUM AUTO (DUAL ARM) CNG DISPENSERS -09 Qty & SINGLE-ARM CNG BUS DISPENSER -02 Qty	Bidder understands that part bid is applicable in this tender, and can bid only for CAR-CUM AUTO (DUAL ARM) CNG DISPENSERS. Kindly Confirm	Part bidding is not applicable for this tender. Tender condition shall prevail.			
10	8.1.5. BEC	10 of 134	The offered CNG Dispenser model must also be approved by the Chief Controller of Explosive (CCOE) Nagpur now PESCO (Petroleum and Safety Organization) and the Bidder shall submit the valid PESCO certificate & their supporting Ramproof items i.e. Exd / Exi/ WP/Exp/Exi Testing approval agency certificates along with the offer.	Our PESCO approval for CAR-CUM AUTO DUAL ARM DISPENSER is at final stage of PESCO approval and is expected by 30.05.2023. We request to you kindly extend the submission of bid till 30.05.2023 or allow us to submit the PESCO approval during bid evaluation stage.	Please refer Corrigendum#02.			

REPLY TO BIDDER'S PRE-BID QUERIES TENDER FOR ANNUAL RATE CONTRACT FOR SUPPLY OF CAR-CUM AUTO DUAL ARM CNG DISPENSERS / SINGLE ARM CNG BUS DISPENSERS FOR CGD IN NORTH GOA TENDER NO. GNGPL/C&PT-50 TENDER ID : VCS21000039			VCS Ref. No.: VCS/GNGPL/1023/PRC/2023/001 Owner - GOA NATURAL GAS PRIVATE LIMITED (GNGPL) Consultant - VCS Quality Services Pvt Ltd. Pre-bid meeting held on 03.05.2023 Date: 22.05.2023					
Sl. No.	Tender Clause No.	Tender Page No.	Description	Bidder's Query/Clarification	GNGPL/VCS Reply			
11	8.1.2, BEC	10 of 134	The bidder should have completed / executed minimum single/multiple purchase order/work order/ Contract as mentioned in below table in the preceding 7 (seven) years reckoned from bid due date for any City Gas Distribution Company and as per following: Definition of Similar Works: Bidder should have designed, fabricated, integrated, tested, & supplied CNG (Dual Arm Car / Single Arm Bus) Dispenser for Natural Gas services of quantity not less than as specified in above table	Bidder understands that the only supply of material shall suffice this clause and this clause does pertain to installation & Commissioning as these are beyond our scope and depends on client's project status. Kindly confirm	Bidder should have designed, fabricated, integrated, tested, supplied, installed & commissioned CNG (Dual Arm Car / Single Arm Bus) Dispenser for Natural Gas services of quantity not less than as specified in above table. Bidder to Submit Completion / Performance Certificate / Commissioning Report issued by end user / CGD entities / as per clause no.8.3 of IFB.			
13	8.3, BEC	10 of 134	vii. Completion / Performance Certificate / Commissioning Report issued by end user / CGD entities / owner linked with above Purchase / Work Order.	Bidder request the clause to be read as quoted "Completion / Performance Certificate / Commissioning Report/Tax Invoice issued by end user / CGD entities / owner linked with above Purchase / Work Order. Kindly confirm	Tender condition shall prevail.			
14	49, PROVISIONS FOR STARTUP		(AS DEFINED IN GAZETTE: NOTIFICATION NO. DL-33004/99 DATED 18.02.2016 AND 23.05.2017 OF MINISTRY OF COMMERCE AND INDUSTRY AND AS AMENDED FROM TIME TO TIME) Not Applicable for this tender.	As per DPE71(4)/2007-Fin. DATED 08.11.2016 OF MINISTRY OF HEAVY INDUSTRIES & PUBLIC ENTERPRISES & OFFICE MEMORANDUM NO.: F. 2072/2014 PPD(p) Dated: 20.09.2016 & 25.07.2015) AS AMENDED FROM TIME TO TIME, major CPSE i.e HPCL, GAIL are giving provision for START UP for developmental order for 10% of tendered quantity. Prior experience as mentioned in technical & financial criteria of BEC shall not be required for all Start-ups (whether Micro & Small Enterprises (MSEs) or otherwise) subject to their meeting the quality and technical specifications specified in tender document. We request you to kindly incorporate the provision for STARTUPS in this bid also.	Tender condition shall prevail.			
15				We have obtained PESO approvals for our CNG Dispenser and wish to participate in the subjected tender. As per your tender BEC, there is no mention of "bidder on behalf of foreign Manufacturer". As this clause is put in tenders by all the PSUs including BPCL, Gail, HPCL etc and also by all PSU owned CGO's (pl refer ongoing tender of IGL), it is requested to kindly include the clause so that we also can participate in your tender.	The bidder should have legal metrology (Model approval certificates) issued by legal metrology (govt. of India) for a CNG dispenser along with a W&M license for Repair, manufacturing & dealer certificates with full fledged technical service support to be provided by the bidder on behalf of a foreign OEM manufacturer as per BEC clause-8.1.6 IFB/tech. vol.1 of IL Also. The bidder should have experience with any City Gas Distribution company from the last 7 years as per BEC criteria for participation in this tender.			
TECHNICAL								
1	7.31	9 of 22	Two number of H-mast with flexible hose arrangement so that the hose doesn't touch the ground.	Kindly include High -Body Frame without H-Mast in the Scope and supply of CNG Car/BUS Dispenser . High Body Frame Provided with more Space which facilitates smooth maintenance of Dispenser and Total Length of the frame shall be approx. 2 m from the base so that venting of gas can be done at safest height.	Tender condition shall prevail			
2	7.35	9 of 22	Complete Stainless Steel (SS316) outer body of cabinet & Body thickness 1.6 mm with door/panel	Kindly note that SS-316 Body frame would increase the overall cost of the Dispenser . However SS-304 Body frame has good corrosion resistance with adequate strength.	Tender condition shall prevail			
3	7.4	10 of 22	Vendor shall also provide surge protection device of approved make at 230 V AC power inlet to protect the dispenser from any electrical surge/spike.	Kindly note that Dispenser Power supply Card has inbuilt surges protection in case of Over-Voltage from incoming power supply. Hence, There is no need for external Surge Protection devices.	To be reviewed during detailed engineering			
4	7.55	12 of 22	Long & venting shall done through 3/8" ID . Long & venting shall done through 3/8" ID	Venting hose of 1/4"ID is generally used for venting of gas which is standard specification of CGD Industries . Venting hose of 3/8" ID doesn't cause more impact for venting of Gas . Request you to kindly include 1/4"ID Hose for Venting of Gas for Bus Dispenser .	Tender condition shall prevail			
5	7.61	13 OF 22	Holder/cradle shall be provided for NGV nozzle and shall be compatible to be attached with NZS-5425 nozzles. Supply of NZS 5425 is in bidder's scope.	Kindly note that There is no requirement of NZS-5424 Nozzle For Bus Nozzle .The same is for Car/Auto Dispenser .	Bidder understanding is correct			
6	8.24	9 OF 29	Suitable differential pressure Gauge across each filter with indication to detect the filter status and to collect the drained oil outside the dispenser by necessary tubing.	Differential Pressure Gauge is generally used to identify Filter Choke/Blockage Condition. As per Rules of Preventive Maintenance for every six Month Filter element should be checked and if found in damaged condition Color of the Filter Element shall turn dark Grey/Black and the same need to be replaced . Hence , There is no extra requirement for Differential Pressure Gauge as extra accessory to the inlet of Bank.	Tender condition shall prevail			
7	8.6	13 of 29	Three actuator valves / Exe proof electronically controlled solenoids per hose outlet (total of 6 valves per dual hose dispenser) and in addition to this there should be one main actuator valve / Exe proof electronically controlled solenoid per hose (After mass flow meter).	Extra solenoid Valve Purpose can be fulfilled by providing the Low Bank Solenoid valve after mass Flow Meter for both sides with Medium and High Bank solenoid Valve shall be in upstream line at Inlet. So , there will be total 6 Solenoid Per Dual Hose Dispenser . Kindly accept the proposed designed .	To be reviewed during detailed engineering, after P&ID review			

			REPLY TO BIDDER'S PRE-BID QUERIES TENDER FOR ANNUAL RATE CONTRACT FOR SUPPLY OF CAR-CUM AUTO DUAL ARM CNG DISPENSERS / SINGLE ARM CNG BUS DISPENSERS FOR CGD IN NORTH GOA TENDER NO. GNGPL/C&PT-50 TENDER ID : VCS21000039			VCS Ref. No.: VCS/GNGPL/1023/PRC/2023/001 Owner - GOA NATURAL GAS PRIVATE LIMITED (GNGPL) Consultant - VCS Quality Services Pvt Ltd. Pre-bid meeting held on 03.05.2023 Date: 22.05.2023 		
Sl. No.	Tender Clause No.	Tender Page No.	Description	Bidder's Query/Clarification	GNGPL/VCS Reply			
8	8.63.1		Hose crimp should be of SS and have protection sleeve over it to avoid short circuit with battery terminal.	Kindly include CS with Chrome Plated Hose Crimp which have adequate corrosion resistance with Chromium addition.	Tender condition shall prevail			
9	Bought out items	3 of 4	Bought Out items -SS VALVES & FITTINGS	Kindly include Hy-Lok-Dk-Lok and Superlok Valves and Fittings in the approved Bought out items. These make are already approved in the Vendor List for all CGD Clients.	Tender condition shall prevail. Hy-Lok-Dk-Lok and Superlok Valves are not accepted.			
10	6. SPECIAL INSTRUCTIONS TO BIDDER	6 OF 8	6.6 The Supplier shall deliver a Certificate confirming to BS EN 10204 3.2 stating the quality, the mechanical properties, the chemical analysis, the process of manufacture for SS tubing & other fittings for complete assembly works.	Stated BS EN 10204 3.2 certification not applicable for Indian Manufacturer. Bidder has ISO 9001 certification and License to manufacture dispensers issued by Legal Metrology Dept. All CGD companies are accepting the dispensers against above certifications only.	BS EN 10204 3.2 certifications shall be applicable for the material inspection report for Bought out items.			
11	7. SCOPE OF SUPPLY & SERVICES	PG 8 OF 22	7.26 Three rows of liquid crystal backlit display for night viewing showing total sale in Rupees (00000.00), quantity of gas sold in kg (0000.00), unit price of CNG in Rs. /kg (0000.00) for each hose on either side of the dispenser (total 4 sets of three rows for each Dispenser, Two set display for each side of display cabinet).	Dispenser shall have below display format as per Dispenser PESO approval. Total sale in Rupees (0000.00). Quantity of gas sold in kg (0000.00). Unit price of CNG in Rs. /kg (0000.00)	Bidder shall provide additional digit (i.e Rupees 00000.00) for future provisions if required at site without any cost implication to GNGPL during CAMC periods.			
12	7. SCOPE OF SUPPLY & SERVICES	PG 11 OF 22	7.48 Dispenser vendor shall keep (multidrop) all the dispensers in common junction box per station in the safe area. Supply of Communication Cables, cable glands, termination of cable and cable laying from dispenser to junction box is in dispenser Vendor's scope. Supply of standard make, WP IP 42 junction boxes, terminal blocks and installation of junction box shall be in dispenser Vendor's scope.	Please confirm qty of Junction box to be considered for supply along with dispensers.	To be confirm during detail engineering			
13	7. SCOPE OF SUPPLY & SERVICES	PG 12 OF 22	For BUS Dispenser 7.55 Fill Hose shall be 1/2" ID 5000 psi (g), at least 4.0 Mtr. Long & venting shall done through 3/8" ID for low noise effects.	For Bus Dispenser Fill hose shall be of 1/2" ID and Vent Hose shall be of 1/4" ID. Please incorporate the same.	Tender Condition shall prevail.			
14	7. SCOPE OF SUPPLY & SERVICES	PG 13 OF 22	7.60 Three rows of liquid crystal backlit display for night viewing showing total sale in Rupees (00000.00), quantity of gas sold in kg (0000.00), unit price of CNG in Rs. /kg (000.00) for each hose on either side of the dispenser (total 4 sets of three rows for each Dispenser, Two set display for each side of display cabinet).	Dispenser shall have below display format as per Dispenser PESO approval. Total sale in Rupees (0000.00). Quantity of gas sold in kg (0000.00). Unit price of CNG in Rs. /kg (0000.00)	Bidder shall provide additional digit (i.e Rupees 00000.00) for future provisions if required at site without any cost implication to GNGPL during CAMC periods.			
15	8.0 DESIGN & ENGINEERING FOR DISPENSER: -	PG 14 OF 22	j) The sales station shall be at CGD of North Goa. The Vendor shall be responsible for supply of dispenser at client stores sites depending upon the availability of sites. The Transportation from client stores to respective sites for erection, installation, testing & commissioning shall be in Vendor's scope.	Bidder shall be responsible for one time transportation at site or store as applicable at the time of dispatch from its plant. If re-transportation is required from site to store then it shall be in scope of client.	Tender Condition shall prevail.			
16	8.8. TECHNICAL SPECIFICATIONS OF MAJOR ITEMS	PG 12 OF 29	FOR DISPENSER CABINET 8.54 Complete cabinet shall be of Stainless Steel (SS316)	Cabinet shall be SS- 304 Grade as per industry standard. There is no operational advantage of using SS 316 grade cabinet. It will unnecessarily increase the cost of dispenser so bidder request to use SS 304 grade Cabinet. No CGD till date is asking for SS 316 grade cabinet body of dispensers.	Tender Condition shall prevail.			
17		PG 108 OF 119	QUALITY ASSURANCE PLAN OF CNG CAR AND BUS DISPENSER	The supplier shall submit its own detailed QAP prepared on the basis of above / Technical specification for approval of Owner/Owner's representative.	Tender Condition shall prevail.			
18	RECOMMENDED VENDOR LIST.	PAGE NO. 2 of 4	PRESSURE RELIEF VALVE	Bidders requests to kindly approve FAINGER LESER make in PRESSURE RELIEF VALVE. It is approved in all other CGD companies.	PTR shall be submitted for approval.			
19	RECOMMENDED VENDOR LIST.	PAGE NO. 2 of 4	TWO WAY / THREE WAY VALVES 2-WAY DRAIN VALVES	Bidders requests to approve DKLOK- KOREA make Two way ball valves. Ddkk is approved for use in CGD companies like MGL, MNGL, GAIL, GAIL GAS LTD, TORRENT GAS LTD, IGL, SABARMATI GAS LTD etc. PTR can be submitted during detailed engineering.	Tender Condition shall prevail.			
20	RECOMMENDED VENDOR LIST.	PAGE NO. 2 of 4	SS TUBING	Bidders requests to approve Ramnamani make SS tubes also. This make is approved for use in CGD companies like MNGL, GAIL, GAIL GAS LTD, IGL, SABARMATI GAS LTD etc.	Tender Condition shall prevail.			

			REPLY TO BIDDER'S PRE-BID QUERIES TENDER FOR ANNUAL RATE CONTRACT FOR SUPPLY OF CAR-CUM AUTO DUAL ARM CNG DISPENSERS / SINGLE ARM CNG BUS DISPENSERS FOR CGD IN NORTH GOA TENDER NO. GNGPL/C&PT-50 TENDER ID : VCS21000039			VCS Ref. No.: VCS/GNGPL/1023/PRC/2023/001		
						Owner - GOA NATURAL GAS PRIVATE LIMITED (GNGPL)		
						Consultant - VCS Quality Services Pvt Ltd.		
						Pre-bid meeting held on 03.05.2023		
						Date: 22.05.2023		
Sl. No.	Tender Clause No.	Tender Page No.	Description	Bidder's Query/Clarification		GNGPL/VCS Reply		
21	RECOMMENDED VENDOR LIST.	PAGE NO. 2 of 5	Valves	Some items are OEM make that are specifically designed and used as per internal instrumentation of dispensers so bidder requests to permit use of OEM make check valves in its dispensers. The check valve is under operation in over 2500 dispenser running in all CGD companies.		PTR shall be submitted for approval.		
22	Clause No. - 4.46, RFID Systems,	PAGE NO. 26 of 29	14. REQUIREMENT FOR AUTOMATION SYSTEM IN DISPENSER i. Identity of vehicle using RFID (In-built option to be provided).	RFID system compatibility in dispensers can only be confirmed after getting specifications of RFID technical specifications from client. Please share the details, so that the same can be incorporated and demonstrated during inspection.		To be confirm during detail engineering		
23	VOL II		LIST OF RECOMMENDED THIRD PARTY INSPECTION AGENCY (TPIA)	Indian register of shipping (IR CLASS) is approved TPIA in major CGD like IOCL, HPCL. Kindly approve IR CLASS as TPIA.		Tender condition shall prevail		
24	VOL II	PAGE NO 115 BOUGHT OUT ITEMS	SS Tubing's	Request you to approve RATNAMANI SS316 SS TUBE as it is used in renowned CGD viz. IGL, MNGL, GUJRAT GAS, AVANTIKA, MGL with proven track record. We shall submit the PTR for the same. Kindly approve		Tender condition shall prevail		
25	VOL II	PAGE NO 115, BOUGHT OUT ITEMS	Ball Valve, Pressure Safety Valve, SS Valves, Fittings	Request you to approve SEALEXCEL SS316 SS FITTINGS & VALVES, Safety Valve as it is used in renowned CGD viz. IGL, MNGL, GUJRAT GAS, AVANTIKA, MGL with proven track record. We shall submit the PTR for the same. Kindly approve		Tender condition shall prevail		
26	VOL II	PAGE NO 115, BOUGHT OUT ITEMS	Solenoid & Electromagnetic Valve	Request you to approve IMI NORGREN as it is used in renowned CGD viz. IGL, MNGL, GUJRAT GAS, AVANTIKA, MGL with proven track record. We shall submit the PTR for the same. Kindly approve		Tender condition shall prevail		
Note: 1. Bidder to submit reply to bidder's queries along with techno-commercial bid documents duly signed and stamped. 2. All other terms and conditions shall remain unchanged as per tender document.								

		CORRIGENDUM #02 TENDER FOR ANNUAL RATE CONTRACT FOR SUPPLY OF CAR-CUM AUTO DUAL ARM CNG DISPENSERS / SINGLE ARM CNG BUS DISPENSERS FOR CGD IN NORTH GOA TENDER NO. GNGPL/C&P/T-50 TENDER ID : VCS21000039			VCS REFERENCE NO. VCS/GNGPL/1023/PRC/2023/001 Owner - GOA NATURAL GAS PRIVATE LIMITED Consultant - VCS Quality Services Private Limited Date: 22.05.2023			
Sl. No.	Clause No.	Page no.	Description		Amendment/ Addition/ Modification/ Deletion			
1	IFB	Clause 7.3, Page No. 8 of 133 (Commercial Vol. I of II)	Tender Document on Sale: 26.04.2023 to 23.05.2023 upto 1430 Hrs.	Modification	Tender Document on Sale: 26.04.2023 to 30.05.2023 upto 1430 Hrs.			
2	IFB	Clause 7.5, Page No. 9 of 133 (Commercial Vol. I of II)	Bid Submission date and time: 23.05.2023 up to 1430 Hrs IST online on e-tendering website: https://www.tenderwizard.com/VCS	Modification	Bid Submission date and time: 30.05.2023 up to 1430 Hrs IST online on e-tendering website: https://www.tenderwizard.com/VCS			
3	IFB	Clause 7.6 Page No. 9 of 133 (Commercial Vol. I of II)	Un-Priced bid opening date and Time: 23.05.2023 up to 1500 Hrs IST online on e-tendering website: https://www.tenderwizard.com/VCS	Modification	Un-Priced bid opening date and Time: 30.05.2023 up to 1500 Hrs IST online on e-tendering website: https://www.tenderwizard.com/VCS			
4	SCC	Terms and mode of Payment (17.0) 73 of 132 (Commercial Volume)	17.1.1 90% (Ninety percent) payment along with freight charges including all taxes & duties will be paid progressively on pro-rata basis on receipt & acceptance of goods at FOT site. 17.1.2 Balance 10% payment shall be released on submission of following document on closure of order	Addition	(In case Installation, Testing & Commissioning and Performance Acceptance Test could not be executed within 90 days from the date of receipt of Dispenser Unit package at site/ store due to reasons attributable to Purchaser, the 10% (Ten Percent) payment shall be released against submission of BG of equivalent amount valid till the Guarantee / Warranty period)			
5	ITB	CONTRACT PERFORMANCE BANK GUARANTEE/ SECURITY DEPOSIT (41.1) 42 of 133 (Commercial Volume)	ITB Clause No.41.1: Within 30 days of the receipt of the notification of award/ FOA from GNGPL, the successful Bidder shall furnish the Contract Performance Guarantee/Security Deposit. The Contract Performance Guarantee shall be in the form of either Banker's Cheque or Demand Draft or Bank Guarantee or Letter of Credit and shall be in the currency of the Contract. However, CPB/SD shall not be applicable in cases wherein the individual order value as specified in Notification of Award is upto INR 5 Lakh (excluding GST). The successful bidder has the option to submit CPB/SD as per the following details: Bidder shall submit CPBG of 10% of Annualized total Contract Value within 30 days of issuance of LOI/ LOA. The Contract Performance Guarantees shall be for an amount as specified in tender documents towards faithful performance of the contractual obligations and performance of equipment/material. For the purpose of Contract Performance Guarantee, Contract Value shall be exclusive of taxes and duties / GST (CGST & SGST/UTGST or IGST).	Modification	The successful bidder shall furnish. Two (02) CPBG's to the purchaser: The Contract Performance Bank Guarantee (CPBG) equivalent to 10% of the total Annualized FOT order value exclusive of taxes & duties within a period of thirty (30) Days from the date of issue of FOA/LOA. The CPBG should initially be kept valid for 90 days beyond the guarantee / warranty period. Another Contract Performance Bank Guarantee (CPBG) equivalent to 10% of the Annualized Comprehensive AMC value (excluding all taxes and duties) to be submitted within thirty (30) Days of start of comprehensive AMC. The CPBG should be valid for 90 days beyond the expiry of Comprehensive AMC period of each year. The proceeds of the Contract Performance Bank Guarantee shall be payable to the Purchaser as compensation for any loss or damage resulting from the Supplier's failure to complete its obligations under the Agreement.			
Note: This Corrigendum shall form an integral part of the bidding document and shall be signed/stamped and submitted along with the bid. All other terms and conditions of tender documents shall remain un-changed.								